

Subject: Bldg. 432/D030 Group Safety Inspection Report

From: Diane Morgan <morgan@aps.anl.gov>

Date: Fri, 02 Sep 2005 12:22:50 -0500

To: Eric Dufresne <dufresne@aps.anl.gov>

CC: Jeffrey Alicz <alicz@aps.anl.gov>, Mark Beno <beno@aps.anl.gov>, Lisa Gades <gades@aps.anl.gov>, Jin Wang <wangj@aps.anl.gov>, Gabrielle Long <gglong@aps.anl.gov>, Efim Gluskin <gluskin@aps.anl.gov>

Division: XFD Location: 432/D030
Date of Inspection: 9/1/05
Inspected by: Jeff Alicz and Jin Wang

The following items were identified during the inspection:

1. The safety shower needs to be tested semi-annually (last test date is 1/7/05). Please contact Glen Kailus (PFS-Maintenance) at 2-7610 to make arrangements for testing.

2. Reminder: A pathway from both the chemical fume hood and the secondary lab door to the eyewash station and safety shower must be kept clear at all times.

***PLEASE SEND A REPLY EMAIL INDICATING THE CORRECTIVE ACTIONS TAKEN.